




SPECIFICATIE TEHNICA COMANDA -COMUNICATIE TABLOU ET AJ 3-TR2 - TE-E.3.2			
NR CRT	DENUMIREA ECHIPAMENTULUI	FABRICAT	BU C
Q0-SD - Q30-SD Q0-SP -	Contact auxiliar semnalizare declansare intrerupator Contact auxiliar semnalizare pozitie intrerupator	Eaton sau similar	54
G	Sursa de alimentare -1-phase, 100-240Vac / 24V DC- 2,5A	Eaton sau similar	1
-A2	Module digitale, I/O module, SmartWire-DT, 24 V CC, 8DI, 8 intrari	Eaton sau similar	6
AD	Adaptor de la cablu plat la cablu rotund SmartWire-DT	Eaton sau similar	2
SWD	Cablu plat -SmartWire-DT- 8 Pini	Eaton sau similar	set
Q27	Intrerupator automat 1P+N/6A, curba C,-Icu= 10kA cu protectie la suprasarcina si scurtcircuit	Eaton sau similar	1



Proiectant de specialitate:	Beneficiar / AUTORITATEA CONTRACTANTA:		
 EDEN DESIGN Nr. Certificat: 01935 Nr. Certificat: 00755 Nr. Certificat: ISO 9001: 2008 ISO 14001: 2004 OHSAS 18001: 2007 S.C. EDEN DESIGN S.R.L., J03/203/1995, CUI RO7116623 Str. Depozitelor nr.8-10, Municipiu Piteşti, Jud. Argeş Tel/fax 0248 610 155; e-mail: office@eden-design.ro; web: www.eden-design.ro;	Spital de Pneumoftiziologie,, Sf. Andrei"-Valea Iasului Amplasament: Com. Valea Iasului		
Proiectat:	Nume	Scara:	Faza project:
ing. Nedelescu Razvan			2/2022
Desenat:	ing. Nedelescu Razvan		PT
Verificat:	ing. Predescu Razvan		Nr.plansa: IECT 81
Data:	MAR 2022		
Titlu planșă:	SCHEMA ELECTRICA COMANDA TABLOU ET AJ3-TR2- TE-E.3.2		