



LEGENDA	
	Traseu de actionare furtun hidrant interior
	Raza de actionare hidrant interior
	Hidrant interior aer-apa cu furtun plat :
	-Debit hidrant interior 2.1 l/s
	-Lungime jet compact hidrant= 10m
	-Raza de actiune 27.74m



Handwritten signature.

NOTA:  
Cladirea se incadreaza in urmatoarele categorii:  
Categorica de importanta: A (exceptionala - conform HG 766/1997)  
Clasa de importanta: I - conform P100-1/2013;  
Grad de rezistenta la focul:  
Risc mic de incendiu - conform P118/1999.

Proiect:	ACTUALIZARE DALI PENTRU OBIECTIVUL DE INVESTITII CONSOLIDARE SI REABILITARE SPITAL JUDETEAN DE URGENTA PITESTI Adresa: Str. Aleea Spitalului nr. 36, ORASUL PITESTI, JUD. ARGES		
Beneficiar:	UNITATEA ADMINISTRATIV TERITORIALA JUDETUL ARGES		
Proiectant general:	ABG BUSINESS TOOLS		
Proiectant instalatii:	ARSTAL SYSTEMS DESIGN S.R.L.		
TITLU PLANSA	INSTALATII SANITARE STINGERE INCENDIU - PLAN SUBSOL		Data: 06/2022 Revizii: 0 Nr. Proiect: 249/21 Scara: 1:200 Faza: D.A.I.L.
Desenat:	ing. Robert Voin	ing. Robert Voin	PLANSA NR. : 13
Proiectat:	ing. Robert Voin	ing. Robert Voin	14
Verificat:	ing. Aurelian Nebunu	ing. Aurelian Nebunu	15
Ser proiect:	arh. Maria Cristina Arghir	arh. Maria Cristina Arghir	16

