



| LEGENDA | |
|---------|---|
| | Traseu de actionare furtun hidrant interior |
| | Raza de actionare hidrant interior |
| | Hidrant interior apa-apa cu furtun plat : |
| | -Debit hidrant interior 2.1 l/s |
| | -Lungime jet compact 10m |
| | -Raza de actiune 27.74m |

DEMISOL PROTEJAT DE HIDRANTI INTERIORI
APA-APA CU FURTUN PLAT
NR. JETURI SIMULTANE - 2 JETURI
DEBIT HIDRANT INTERIOR = 2.1 l/s
DEBIT INSTALATIE HIDRANTI = 4.2 l/s
LUNGIME JET COMPACT HIDRANT = 10.0m
RAZA DE ACTIUNE HIDRANT 27.74 m



[Signature]

NOTA:
Cladirea se incadreaza in urmatoarele categorii:
Categoriza de importanta: A (exceptionala - conform HG 766/1997)
Clasa de importanta: I - conform P100-1/2013;
Grad de rezistenta la focul:
Risc mic de incendiu - conform P118/1999.

| | | | |
|------------------------|--|--|-----------------------------|
| Proiect: | ACTUALIZARE DALI PENTRU OBIECTIVUL DE INVESTITII CONSOLIDARE SI REABILITARE SPITAL JUDETEAN DE URGENTA PITESTI Adresa: Str. Alea Spitalului nr. 36, ORASUL PITESTI, JUD. ARGES | | |
| Beneficiar: | UNITATEA ADMINISTRATIV TERITORIALA JUDETEL ARGES | | |
| Proiectant general: | ABG BUSINESS TOOLS | | |
| Proiectant instalatii: | ARSTAL SYSTEMS DESIGN S.R.L. | | |
| TITLU PLANSA | INSTALATII SANITARE STINGERE INCENDIU - PLAN DEMISOL | | PLANSA NR. : IS02 |
| | Data: 06/2022 Revizie: 0 Nr. Proiect: 249/21 Scara: 1:200 Faza: D.A.I.L. | | |
| | Desenat : ing. Robert Voin Proiectat : ing. Robert Voin Verificat : ing. Aurelian Nebunu Ser proiect : arh. Maria Cristina Arghir | | |
| | | | |