



LEGENDA	
	Traseu de actionare furtun hidrant interior
	Raza de actionare hidrant interior
	Hidrant interior apa-apa cu furtun plat :
	-Debit hidrant interior 2.1 l/s
	-Lungime jet compact 10m
	-Raza de actiune 27.74m



Handwritten signature of the project engineer.

NOTA:
Cladirea se incadreaza in urmatoarele categorii:
Categororia de importanta: A (exceptionala - conform HG 766/1997)
Clasa de importanta: I - conform P100-1/2013;
Grad de rezistenta la focuII;
Risc mic de incendiu - conform P118/1999.

Proiect:	ACTUALIZARE DALI PENTRU OBIECTIVUL DE INVESTITII CONSOLIDARE SI REABILITARE SPITAL JUDETEAN DE URGENTA PITESTI Adresa: Str. Aleea Spitalului nr. 36, ORASUL PITESTI, JUD. ARGES		
Beneficiar:	UNITATEA ADMINISTRATIV TERITORIALA JUDETUL ARGES		
Proiectant general:	ABG BUSINESS TOOLS		
Proiectant instalatii:	ARSTAL SYSTEMS DESIGN S.R.L.		
TITLU PLANSA	INSTALATII SANITARE STINGERE INCENDIU - PLAN ETAJ 3		PLANSA NR. : IS06
Desenat : Proiectat : Verificat : Ser proiect :	ing. Robert Voin ing. Robert Voin ing. Aurelian Nebunu arh. Maria Cristina Arghir		Data: 06/2022 Revizie: 0 Nr. Proiect: 249/21 Scara: 1:200 Faza: D.A.I.I.